

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8110-2212:0502 Page 1 of 1

**CATEGORY:** 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** UFP Ventures II, Inc. 1801 E. Lessard Street, Prairie du Chien, WI 53821  
Contact: Robert Rottinghaus (608) 371-1115  
Email: rrottinghaus@ufpi.com

**DESIGN:** DeckOrators TG2 Slotted and Solid Edge Composite Decking, material 1" x 5-1/2" with a maximum edge-to-edge spacing of 3/16". Attached to nominal 2" x 6" Douglas-fir joists, 16" O.C.

Refer to manufacturer's installation instructions and product data sheets.

**RATING:** Class B Flame Spread

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and SFM label.

**APPROVAL:** Listed as decking materials for use in the Wildland Urban Interface areas when attached exterior wall covering complies with California Building Code 707A. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Test Protocol SFM 12-7A-4A

Burning brand exposure test with "B" brand also conducted and met Conditions of Acceptance of SFM 12-7A-4, Part B.

05-21-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

*Listing Expires* **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*