

Issue Date: 10-01-2015  
Revision Date: 12-18-2025  
Renewal Date: 12-31-2026

**DIVISION: 06 00 00 – WOOD, PLASTICS AND COMPOSITES**  
**Section: 06 50 00 – Structural Plastics**  
**Section: 06 53 00 – Plastic Decking**

**REPORT HOLDER:**

**Eovations, LLC**  
5 Meadowcraft Parkway  
Selma, AL 36701  
(334) 872-1580  
[www.Deckorators.com](http://www.Deckorators.com)

**REPORT SUBJECT:**

**Eovations™ Deck Boards**

*Deckorators® Porch Boards*  
*Deckorators® Vault Deck Boards also known as*  
*Deckorator®s Voyage, Deckorators® Summit,*  
*Deckorators® Excursion, and Eovations Tractio*  
*Deckorators® Frontier Deck Boards*  
*Deckorators® Voyage Varied-Plank Decking*  
*Deckorators® Dock and Deck Board*  
*SLS Composite Deck Boards*  
*Ultra Light Deck Boards*

### 1.0 SCOPE OF EVALUATION

1.1. This research report addresses compliance with the following Codes:

- 2024, 2021, 2018 *International Building Code®* (IBC)
- 2024, 2021, 2018 *International Residential Code®* (IRC)

NOTE: This report references the most recent edition of the codes cited Section numbers in earlier editions may differ.

1.2. Deck and porch boards have been evaluated for the following properties:

- Structural Performance
- Durability
- Surface Burning

1.3. *Eovations™, Deckorators®, SLS Composite, Ultra Light* deck and *Porch* boards are intended for use as a walking surface on exterior decks, balconies, porches, and walkways,

including stairs in One- and Two-Family Dwellings regulated by the IRC and other construction types regulated by the IBC in accordance with IBC Section 705.2 *Projections*, where fire-resistance rated floor construction is not required for the deck or balcony.

### 2.0 STATEMENT OF COMPLIANCE

*Eovations™, Deckorators®, SLS Composite, Ultra Light* deck and *Porch* boards comply with the Codes listed in Section 1.1, for the properties stated in Section 1.2 and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in Section 6.0.

#### 2.1 2024 IBC and IRC Evaluation Reports

The Intertek CCRR is an *Evaluation Report* for approval of an alternate material, design, or method of construction in accordance with Section 104.2.3.6.1 of the 2024 IBC and Section R104.2.2.6.1 of the 2024 IRC.

### 3.0 DESCRIPTION

3.1. *Eovations™, Deckorators®, SLS Composite, Ultra Light Deck Boards* are thermoplastic composite deck boards, co-extruded using proprietary inorganic fillers and polypropylene (PP) materials with a polypropylene cap.

3.2. Finished deck boards are available in solid or slotted rectangular profiles.

3.2.1. *Eovations™* deck boards are provided with nominal dimensions of 5.3 inches wide and 0.75 inches thick. See Figure 1.

3.2.2. *SLS Composite* and *Ultra Light* deck boards are provided with nominal dimensions of 5.2 inches wide and 0.800 inches thick. See Figure 2.





**3.2.3.** *Deckorators® Vault* and *Frontier* deck boards are provided with nominal dimensions of 5.5 inches wide and 0.835 inches thick. See Figure 3.

**3.2.4.** *Deckorators® Voyage Varied-Plank Decking* is provided with nominal dimensions of 3.5 inches, 5.5 inches, 7.25 inches, 9.25 inches, and 11.25 inches wide and 0.835 inch thick. See Figures 6-8.

**3.2.5.** *Deckorators® Dock & Deck Board* is provided in nominal dimensions of 5.5 inches wide and 1.21 inches thick. See Figure 5.

**3.3.** *Deckorators® Porch* boards are provided with a tongue and groove profile of nominal dimensions of 3.125 inches wide and 0.835 inches thick and 5.125 inches wide and 0.835 inches thick referenced as 3.5" and 5.5". See Figure 4.

**3.4.** Deck boards may be installed via face-fastening using exterior screws or by using hidden fastener systems.

#### 4.0 PERFORMANCE CHARACTERISTICS

**4.1.** Deck and porch boards are rated for a uniform live load of 100 lbs/ft.<sup>2</sup> when installed on support framing spaced at up to 16 or 24 inches (See Table 2).

**4.2.** Deck and porch boards used as stair treads are rated for the code-prescribed concentrated load equal to 300 lbs. when installed as a continuous board over a minimum of two spans with the maximum span specified in Table 2.

**4.3.** Deck and porch boards have wind uplift resistance ratings as determined by the fastening method. See Table 2.

**4.4.** Materials used have a flame spread index no greater than 200 when tested in accordance with ASTM E84.

**4.5.** Materials are deemed equivalent to preservative treated or naturally durable wood for resistance to weathering effects, attack from termites and fungus decay.

**4.6.** Structural performance has been demonstrated for a temperature range from -20°F to 125°F.

#### 5.0 INSTALLATION

Installation shall be in accordance with the manufacturer's installation instructions and this report. Where differences occur between this report and the manufacturer's installation instructions, this report shall govern.

**5.1.** Solid deck boards may be face-fastened with (2) #7 x 1-7/8-inch *Camo™* coated steel screws at every joist or edge-fastened with (2) *Camo™ Edge* deck screws installed at 45° at every joist. 11.25-inch-wide solid deck boards may also be face-fastened with (2) #8 x 2-1/2 in stainless steel deck screws at every joist.

**5.2.** Slotted deck boards are installed with the *Equator®*, *Camo™ EdgeClip* and *EdgeX Clip*, *Stowaway™*, *StealthLock™*, or *DeckWise* hidden fastener systems. One fastener is required at every joist. See Figure 9.

**5.3.** Tongue and groove porch boards are installed with the "T" or "L" cleat nails. One nail is required at every joist. See Figure 10.

#### 6.0 CONDITION OF USE

The deck board applications identified in this report are deemed to comply with the intent of the provisions of the referenced building codes subject to the following conditions:

**6.1.** Deck and porch boards placed at an angle other than 90 degrees to the supporting joist will require support framing at a reduced spacing such that the span of the board does not exceed the span rating specified in Table 2).

**6.2.** The wind uplift resistance rating recognized in this report is based on attachment to treated Southern Pine framing (specific gravity, G=0.55). Installation on wood framing with a lesser specific gravity may result in a lower wind uplift rating.

**6.3.** Where required by the building official, engineering calculations and details shall be provided. The calculations shall verify that the anchorage complies with the building code for the type of framing and condition of the supporting construction.





6.4. Compatibility of the supporting construction materials with all metal fasteners are subject to approval by the code official.

6.5. Only those types of fasteners and fastening methods described in this report have been evaluated for the installation of the deck boards; other methods of attachment are outside the scope of this report.

6.6. *Eovations™, Deckorators®, SLS Composite, Ultra Light Deck and Porch* boards are manufactured in accordance with the manufacturer's approved quality control system with inspections by Intertek Testing Services NA, Inc.

7.0 SUPPORTING EVIDENCE

7.1. Manufacturer's drawings and installation instructions.

7.2. Reports of testing and engineering analysis demonstrating compliance with ICC-ES AC174, Acceptance Criteria for Deck Board Span Ratings and Guardrail Systems (Guards and Handrails), approved January 2025, and ASTM D7032-21.

7.3. Documentation of an Intertek approved quality control system for the manufacturing of products recognized in this report.

8.0 IDENTIFICATION

*Eovations™, Deckorators®, SLS Composite, Ultra Light* deck and porch boards produced in accordance with this report shall be identified with labeling on the individual deck boards that includes the following information: Name and/or trademark of manufacturer; the Code Compliance Research Report identification and number (CCRR-0195); and the following statement: "See Intertek CCRR-0195 at <https://bpdirectory.intertek.com> for uses and performance levels."



9.0 OTHER CODES

This section is not applicable.

10.0 CODE COMPLIANCE RESEARCH REPORT

10.1. Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2. Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

10.3. Reference to the Intertek website address: <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.





TABLE 1 - PROPERTIES EVALUATED

PROPERTY	APPLICABLE CODE SECTIONS <sup>1</sup>	
	2024 IBC	2024 IRC
Physical properties	2612	R507.2.2
Surface burning characteristics	2612.3	R507.2.2.2
Combustible projections	705.2	R302.1
Live loads	1607	R301.5
Wind loads	1609	R301.2.1
Anchorage	1604.8.3	R507.8.9

<sup>1</sup>Section numbers pertain to the most recent edition cited in Section 1.1 of this Report.

TABLE 2 – SPAN AND UPLIFT RESISTANCE RATINGS

Product	Live Load (in / psf)	Stair Tread Support Spacing <sup>(1)</sup>	Fastener <sup>(2)</sup>	Uplift Resistance
<b>Eovations™ Deck Boards</b> <i>Eovations™ Tractio</i> <i>Deckorators® Vault Deck Boards</i> <i>Deckorators® Voyage</i> <i>Deckorators® Summit</i> <i>Deckorators® Excursion</i> <i>Deckorators® Frontier Deck Boards</i> <i>SLS Composite Deck Boards</i> <i>Ultra Light Deck Boards</i>	16 / 100	9 inches	#7 x 1-7/8" <i>Camo™</i> coated steel screws	77 psf
			<i>Equator®</i> Hidden Fastener	44 psf
			<i>Stowaway™</i> Hidden Fastener	105 psf
			<i>StealthLock™</i> Hidden Fastener	108 psf
3.5" <i>Deckorators®</i> Porch	16 / 100	9 inches	"L" cleat nail	127 psf
5.5" <i>Deckorators®</i> Porch			"T" cleat nail	138 psf
			"L" cleat nail	81 psf
			"T" cleat nail	88 psf
3.5", 5.5", 7.25" <i>Deckorators®</i> <i>Voyage Varied-Plank Decking</i>	16 / 100	9 inches	<i>Camo®</i> Edge Deck Screws	133 psf
			<i>Stowaway™</i> Hidden Fastener	105 psf
			<i>StealthLock™</i> Hidden Fastener	108 psf
			<i>Camo®</i> EdgeClip Hidden Fastener	150 psf
			<i>DeckWise</i> Hidden Fastener	150 psf
9.25" <i>Deckorators®</i> Voyage <i>Varied-Plank Decking</i>	16 / 100	9 inches	#7 x 1-7/8" <i>Camo™</i> coated steel screws	94 psf
			<i>Stowaway™</i> Hidden Fastener	116 psf
			<i>StealthLock™</i> Hidden Fastener	108 psf
			<i>Camo®</i> EdgeClip Hidden Fastener	85 psf
11.25" <i>Deckorators®</i> Voyage <i>Varied-Plank Decking</i>	16 / 100	8 inches <sup>(3)</sup>	#8 x 2-1/2 inches stainless steel deck screws	197 psf
			#7 x 1-7/8" <i>Camo™</i> coated steel screws	97 psf
<i>Deckorators®</i> Dock & Deck Board	24 / 100	12 inches	<i>Camo®</i> Edge Deck Screws	125 psf

<sup>(1)</sup> Continuous two-span installation.

<sup>(2)</sup> As described in Table 3.

<sup>(3)</sup> 11.25" stair treads are secured with three #8 x 2-1/2 inches stainless steel deck screws at each stair support.





TABLE 3 - FASTENER DESCRIPTION AND USES

Generic Fastener Description	Uses	Detailed Fastener Description
#8 x 2-1/2 inches stainless steel deck screw	For 11.25" wide solid deck boards (see Section 5.1)	9 TPI, 2.468 in overall length, 0.177 in major diam., 0.115 in minor diam., 0.128 in shank diam., 0.250 in head diam., star drive, trim head, type 17 point
#7 x 1-7/8 inches <i>Camo</i> <sup>™</sup> coated steel screw	Face fasteners for solid deck boards (see Section 5.1)	9 TPI with a 0.43-inch length of reverse pitch, 1.85-inch overall length, 0.162-inch major diameter, 0.197-inch head diameter, star drive trim head, pinch point
<i>Camo</i> <sup>®</sup> <i>Edge</i> Deck Screw (Figure 9)	Hidden fastening system for solid deck boards (See Section 5.1)	#7 x 2-3/8-inch ( <i>Dock &amp; Deck</i> decking) or 1-7/8-inch ( <i>Voyage</i> decking) 316 stainless steel screw (0.157-inch major diameter, 0.114-inch shank diameter, 0.200-inch head diameter)
<i>Camo</i> <sup>®</sup> <i>Edge</i> Clip and <i>EdgeX</i> Clip Hidden Fasteners (Figure 9)	Hidden fastening systems for slotted deck boards (See Section 5.2)	Nylon spacer body with 304 stainless steel gusset and #7 x 2-1/4-inch 401 stainless steel screw (0.167-inch major diameter, 0.122-inch shank diameter, 0.200-inch head diameter)
<i>Equator</i> <sup>®</sup> Hidden Fastener (Figure 9)	Hidden Fastening system for slotted deck boards (see Section 5.2)	Polypropylene Clips 10 TPI with a 2-inch overall length, 0.170-inch major diameter, 0.242-inch head diameter, square drive trim head, type 17 point
<i>Stowaway</i> <sup>™</sup> Hidden Fastening System (Figure 9)	Hidden Fastening system for slotted deck boards (see Section 5.2)	Nylon Composite Clips fastened to joists with #7 by 1-5/8-inch-long stainless-steel screw (0.164-inch major diameter, 0.124-inch shank diameter, 0.235 in head diameter)
<i>StealthLock</i> <sup>™</sup> Hidden Fastening System (Figure 9)	Hidden Fastening system for slotted deck boards (see Section 5.2)	Nylon Composite Clips fastened to joists with #8 by 1-3/4-inch-long stainless-steel screw (0.166-inch major diameter, 0.118-inch shank diameter, 0.200 in head diameter)
<i>DeckWise</i> Hidden Fastener (Figure 9)	Hidden Fastening system for slotted deck boards (see section 5.2)	#8 by 2 in long (0.178 in major dia., 0.117 in minor dia., 0.134 in shank dia., 1.360 in threaded shank, 8 TPI, type 17 point) grade 305 stainless steel, T15 drive,
"L" cleat nail (Figure 10)	Fastening system for tongue and groove porch boards (see Section 5.2)	16-gauge x 2 inches Freeman "L" Cleat Flooring Nail installed using a pneumatic flooring tool
"T" cleat nail (Figure 10)	Fastening system for tongue and groove porch boards (see Section 5.2)	16-gauge x 2 inches Freeman "T" Cleat Flooring Nail installed using a pneumatic flooring tool



Intertek

545 E. Algonquin Road • Arlington Heights • Illinois • 60005

[intertek.com/building](http://intertek.com/building)ACCREDITED  
Product Certification  
Agency

PCA-101




FIGURE 1 – EOVATIONS™ DECK BOARD PROFILE




FIGURE 2 – SLS COMPOSITE AND ULTRA LIGHT DECK BOARD PROFILES




FIGURE 3 – DECKORATORS® (VAULT, VOYAGE, SUMMIT, EXCURSION, AND FRONTIER) AND EOVATIONS™ TRACTIO DECK BOARD PROFILES






FIGURE 4 – DECKORATORS® PORCH PROFILES (TONGUE AND GROOVE)




FIGURE 5 – DECKORATORS® DOCK & DECK BOARD




FIGURE 6 – 7.25" DECKORATORS® VOYAGE VARIED-PLANK DECKING






FIGURE 7 – 9.25" DECKORATORS® VOYAGE VARIED-PLANK DECKING





FIGURE 8 – 11.25" DECKORATORS® VOYAGE VARIED-PLANK DECKING







Equator® Hidden Fastener System




StealthLock™ Hidden Fastener System




EdgeClip Hidden Fastener System



EdgeX Clip Hidden Fastener System



DeckWise Hidden Fastener System



Stowaway™ Hidden Fastener System

FIGURE 9 – DECK BOARD FASTENERS



“L” Cleat Nail (16 gauge, 2”)



“T” Cleat Nail (16 gauge, 2”)

**FIGURE 10 – PORCH FASTENERS**