



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8110-2212:0500
CATEGORY:	8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	UFP Ventures II, Inc. 1801 E. Lessard Street, Prairie du Chien, WI, 53821 Contact: Oesterle, Timothy (608) 778-1005 Email: toesterle@ufpi.com
DESIGN:	DecKorators Classic, Vista and Heritage composite grooved edge deck board, 7/8" minimum thickness x 5 1/2" minimum width with 1/8" maximum edge-to-edge spacing. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name. Model number, rating and SFM label.
APPROVAL:	Listed as decking materials for use in the Wildland Urban Interface areas.
NOTES:	Test Protocol SFM 12-7A-4A

08-10-2017 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/12/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division